

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1429:123 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Secutron, Div. of Digital Security Controls LTD, 3301 Langstaff Rd, Concord, ON L4K 4L2
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models MR28-9001, MR28-9003 Dialer Modules and MR28-9002, MR28-9004
Dialer/Isolator Modules. Refer to listee's data sheet for additional detailed product
description and operational considerations.

RATING: 19 to 27.5 VDC, 24 VDC nominal

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances
and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed Model MR-2900
(CSFM Listing No. 7165-1429:100 or 7170-1429:105) fire alarm control unit. Refer to listee's
Installation Instruction Manual for details.

12-17-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**